

# Netanya II



Tuesday, 2<sup>nd</sup> July 1997

To whom it may concern,

Situation: Barnacle/scale buildup-internal pipes  
Solution: Trac Barnacle Buster  
Application date: 06/28/97

The Netanya II called in the services of Trac Ecological Products of U.S.A. Inc. to remove scale and barnacles from raw water air conditioning (A/C) system. Our system consists of 2 A/C condensers and about 100 feet of pipe. The Trac Cleaning System was brought on site to Bradford Marine. The technicians started the work by adapting the A/C system to fit the Trac Cleaning System, their pre-pressure test revealed a leak behind an electrical transformers and a leaking sea strainer, which took approximately three hours to repair with the help of the ship's first Mate.

After the cleaning system was installed, the circulation of the Trac Barnacle Buster took place for a period of five hours. The product was recovered into the tanks, which are located within the Trac Cleaning trailer. The system was opened for inspection. The result of this cleaning was great; there were no traces of barnacles left in the system. The system was put back in operations and began to cool perfectly.

Because of the satisfying results, the quickness, ease of application, and the environmental safety, this procedure is highly recommended by the Crew of the Netanya II.

Sincerely,

Terry S. Jette  
1<sup>st</sup> Mate / Chief Engineer