

**Cooling Tower cleaning instructions**

**Why should I use TRAC'S DESCALER® Concentrate?**

- Scale deposits in closed water cooled system can dramatically reduce heat transfer. As little as 1/64" of scale build-up can reduce system efficiency by as much as 15%. Although there are many descalers on the market today, most are Hydrochloric acid based and can easily damage the equipment. Only TRAC'S DESCALER® Concentrate can safely remove scale, rust and lime build-ups from deep within the system, TRAC'S DESCALER® Concentrate is 100% biodegradable and safe to both user and equipment.

**How much of TRAC'S DESCALER® do I need?**

- To determine how much TRAC'S DESCALER® Concentrate you need, simply multiply the appropriate percentage (from the table below) by the system's water capacity.

Build Up	Description	%
Light Scale	Deposits are light in color and spaced out.	2.5%
Heavy Scale	Mineral deposit is thick and found throughout the system.	5%

**When to use TRAC'S DESCALER® Concentrate?**

- When doing your yearly inspection of your chiller and you notice a scale built up on your tubes.
- When your delta T has a differential of more than 7.
- If your cooling tower fill has scale built up or algae.
- If you notice built up at the bottom of your cooling tower pan.

**Cleaning Instructions:**

- Determine the systems total water capacity by adding up the length of the different size piping, capacity of the cooling tower and any chillers. Refer to our Pipe Gallonage Chart to determine the capacity of different size of piping.
- Turn off the systems make up water and bleed.



- Drain cooling tower pan to where water level is at a minimum, making sure not to drain to much, or the pump might cavitate.
- Using the chart above and the systems capacity, slowly add the proper amount of TRAC'S DESCALER® Concentrate in the cooling tower. Let the system recirculate for a minimum of 10 hours.
- After 10 hours of circulation, turn make up water and bleed back on. This will help remove the dissolved residue.
- To remove all residue from the system, it is recommended that the cooling towers drain valve is opened and the make up water added.

**Warning**

- A hot boiler will increase the aggressiveness of the solution. In this instance, lower the solutions circulating times.
- It is recommended to have defoamer on hand as many boilers contain calcium build up from the salts used in treating water hardness. Standard carpet cleaner defoamer will work.